




WALRUS

直立浸水式泵浦 TPHK Immersible Pump

使用說明書
Installation Manual

IE3/IE4 高效率馬達
High Efficiency Motor



ISO 9001

大井泵浦工業股份有限公司
WALRUS PUMP CO., LTD.

EC Declaration of Conformity

Manufacturer:

Walrus Pump Co., Ltd.

Address:

No.83-14, Dapiantou, Sanzhi Dist., New Taipei City 252, Taiwan

Declare that the machinery described:

Name : Water Pump

Model : TPHK Series

Conform to the following directive:

2006/42/EC—Machinery directive

2014/35/EU—Low voltage directive

2014/30/EU—EMC (Electromagnetic compatibility) directive

2009/125/EC— Ecodesign Directive

Electric motors:

Commission Regulation No 640/2009.

Applies only to three-phase Walrus motors marked IE3/IE4.

See motor nameplate.

Standard used: EN 60034-30:2009.

Refer to the following standards:

EN ISO 12100:2010

EN ISO 13857:2008

EN 809:1998+A1:2009

EN 60204-1:2006

EN 60335-1:2012

EN 60335-2-41:2003+A2:2012

EN 61000-6-2:2005

EN 61000-6-3:2007

R&D department manager: Kao Tien-chuan

Manager:





Please read this instruction manual carefully before installing your new system as failures caused by incorrect installation and operation are not covered by the warranty.

1. Application

- 1.1. The TPHK series is multi-stage centrifugal pump designed for industrial use, especially for machine tools.
- 1.2 The pump can not be used to transfer explosive liquids; such as gasoline, diesel oil or similar liquids. It is suitable to carry liquids such as water, coolant, low viscosity or other non-corrosive liquids.





2. Product Code Designation

The standard range of pumps includes complete impeller in chamber combinations. Upon request, a special length can be supplied by fitting empty intermediate chambers instead of standard chambers with impellers. The pump nameplate indicates the number of chambers and impellers fitted to the pump.

3. Operating Limits

1. Ambient temperature : Max. 40°C(104°F)
2. Liquid temperature range : 0°C(32°F) to 90°C(194°F)
3. Operating pressure : Max. 10 kg/cm²
4. Submerged depth : Min. 40mm
5. Stainer Diameter : Ø2mm(TPHK2T,4T)
Ø3mm(TPHK8T,12T)
6. Particle Size : 2mm(TPHK2T,4T)
3mm(TPHK8T,12T)
7. Liquids(maximum content of solid particles in suspension 50g/m³)
8. Kinematical Viscosity : 32 cst (mm²/s)
9. Stops and Restarts :

Output power[kW]	times/hour
Below 2.2	250
2.2~4.0	100



4. Installation




The pump has hot surface on the motor. It must be installed so that persons cannot accidentally come into contact the hot surface.

4.1. Submerged Depth

To avoid dry running and damage the pump during operation, the minimum pump submerged depth is 40mm(1 $\frac{5}{8}$ ") as shown in Fig 1. In addition, the bottom of the pump suction inlet must be at least 25 mm (1") above the bottom of the tank.

Fig.1



4.2. We recommend outlet should stay the same size as the original. If you narrow the pipe size, it will affect the performance of the pump.

5. Electrical Connection



5.1 The electrical connection should be carried out in accordance with local regulations. Never make any connections unless the electricity supply has been switched off.



5.2. The electrical hazard warning mark is placed outside the connection box. Be careful.

5.3. Electrical data (voltage and frequency) are shown on the pump nameplate. Verify if these data match your electricity supply. A circuit breaker should be installed and the grounding be properly connected for your safety.

- 5.4. Make electrical connection in accordance with connecting diagram located inside the connection box. The motor current must be within the rated amps range indicated on nameplate. Three phase motor requires a magnetic starter for safety.
- 5.5. For three phase motors, please check the correct direction of rotation of the pump on the motor fan cover. When seen from motor fan cover end, the pump should rotate clockwise. You can reverse the direction of rotation by interchanging any two of the incoming supply wires.
- 5.6. For your safety, be sure the Residual current device (RCD, 30mA) is in your system and grounding is properly connected to prevent from electric shock.
- 5.7. If the supply cord is damaged, it must be replaced by the manufacturer, its service agent or similiary qualified persons in order to avoid a hazard.
- 5.8. The user shall install a over-load protection device for the pump runing.

6. Start-up

Before starting the pump, make sure the following:

- 6.1. For three phase motors, verify if the rotating direction is correct. It should be clockwise viewing from the motor fan cover end.
- 6.2. All piping joints are completely tight. Leakage in piping may cause the pump hydraulic loss.
- 6.3. The pump is filled with liquid.
- 6.4. The suction filter is not blocked by any foreign objects.

7. Operation and Maintenance



It is dangerous to operate the pump against a closed discharge outlet because it will

cause extremely high liquid flow temperature and damage the pump in a few minutes.

7.1. Lubrication

The mechanical seal and shaft sleeves are lubricated by the pumped liquid.

7.2. Suction filter

Always keep suction filter clean and make sure it is not blocked by impurities.

7.3. Periodic checks

The following checks should be carried out periodically to ensure the normal operation.

7.3.1. Check the quantity of liquid and operating pressure.

7.3.2. Check there are no leaks on piping joints.

7.3.3. Check the tripping of the motor starter.

7.3.4. Check that all controls are functioned normally.

7.4. When pump is not in use for a period, it should be drained. For start up after long time inactivity please check if the impeller and mechanical seal are free. If they are locked up by sand, rust or something else please clean them up.

7.5. The pump must not be used to transfer explosive liquids. In systems with hot liquids (over 60°C), extra caution should be exercised to prevent from personal injury.

7.6. The pump should not be used to transfer toxic or contaminated liquids. Please carefully follow all instructions in the manual as Walrus may refuse to accept the contaminated pump for servicing.

7.7. If the supply cord is damaged, it must be replaced by a special cord or assembly available from the manufacturer or its service agent.

8. Sound pressure level

Motor	dB(A)
TPHK2T ** - 1	<70
TPHK2T ** - 2	<70
TPHK2T ** - 3	<70
TPHK2T ** - 4	<70
TPHK2T ** - 5	<70
TPHK2T ** - 6	<70
TPHK2T ** - 7	<70

Motor	dB(A)
TPHK4T ** - 1	<70
TPHK4T ** - 2	<70
TPHK4T ** - 3	<70
TPHK4T ** - 4	<70
TPHK4T ** - 5	<70
TPHK4T ** - 6	<70

Motor	dB(A)
TPHK8T ** - 2	<70
TPHK8T ** - 3	71
TPHK8T ** - 4	76
TPHK8T ** - 5	76


Motor	dB(A)
TPHK8T**-2E	<70
TPHK8T**-3E	76
TPHK8T**-4E	76
TPHK8T**-5E	76
TPHK8T**-6E	76

Motor	dB(A)
TPHK12T ** - 1	71
TPHK12T ** - 2	76
TPHK12T ** - 3	76

Above drawing shows the noise level while pump operated with closed outlet.

The tolerance of noise level is ±3dB(A).

9. Wiring diagram





10. Fault Finding

Make sure electricity supply has been switched off before attempting to diagnose any fault.

Fault	Cause
10.1 Motor does not start	a. No electricity supply
	b. Fuses are blown.
	c. Motor overheating relay tripped.
	d. Defective magnetic contactors.
	e. Control circuit malfunction.
10.2. Motor cut out during operation.	a. Fuses blown or breakers tripped.
	b. Overheating relay tripped.
	c. Control circuit malfunction.
	d. Pump locked up by foreign objects.
10.3. Pumped capacity is not constant.	a. Pump impeller blocked by impurities.
	b. Insufficient liquid level in the tank. (See Sec. 4.1)
10.4. Pump runs but gives no liquid.	a. Suction filter blocked by impurities.
	b. Liquid level is too low (See Sec. 4.1)
	c. Incorrect rotating direction.


11. Dimensions

TPHK 2T/4T




Model	A (mm)	B (mm)	L (mm)
TPHK 2T 3 -1	205.5	144	349.5
TPHK 2T 8 -1	205.5	234	439.5
TPHK 2T 3 -2	205.5	144	349.5
TPHK 2T 5 -2	205.5	180	385.5
TPHK 2T 9 -2	205.5	252	457.5
TPHK 2T 3 -3	205.5	144	349.5
TPHK 2T 4 -3	205.5	162	367.5
TPHK 2T 5 -3	205.5	180	385.5
TPHK 2T 6 -3	205.5	198	403.5
TPHK 2T 8 -3	205.5	234	439.5
TPHK 2T11-3	205.5	288	493.5
TPHK 2T 4 -4	245.5	162	407.5
TPHK 2T 6 -4	245.5	198	443.5
TPHK 2T 5 -5	245.5	180	425.5
TPHK 2T 6 -5	245.5	198	443.5
TPHK 2T 6 -6	253.5	198	451.5
TPHK 2T 8 -6	253.5	234	487.5
TPHK 2T 9 -6	253.5	252	505.5
TPHK 2T10-6	253.5	270	523.5
TPHK 2T11-6	253.5	288	541.5
TPHK 2T 7 -7	284	216	500
TPHK 4T 2 -1	205.5	144	349.5
TPHK 4T 3 -1	205.5	171	376.5
TPHK 4T 2 -2	245.5	144	389.5
TPHK 4T 3 -2	245.5	171	416.5
TPHK 4T 4 -2	245.5	198	443.5
TPHK 4T 6 -2	245.5	252	497.5
TPHK 4T 3 -3	245.5	171	416.5
TPHK 4T 4 -3	245.5	198	443.5
TPHK 4T 5 -3	245.5	225	470.5
TPHK 4T 6 -3	245.5	252	497.5
TPHK 4T 8 -3	245.5	306	551.5
TPHK 4T 4 -4	284	198	482
TPHK 4T 5 -4	284	225	509
TPHK 4T 6 -4	284	252	536
TPHK 4T 5 -5	309	225	534
TPHK 4T 8 -5	309	306	615
TPHK 4T 6 -6	309	252	561
TPHK 4T 8 -6	309	306	615

TPHK 8T/12T



Model	A (mm)	B (mm)	L (mm)
TPHK 8T 6 -2	369	196.5	565.5
TPHK 8T 9 -2	369	298.5	667.5
TPHK 8T 3 -3	369	94.5	463.5
TPHK 8T 6 -3	369	196.5	565.5
TPHK 8T 9 -3	369	298.5	667.5
TPHK 8T 4 -4	416	128.5	544.5
TPHK 8T 6 -4	416	196.5	612.5
TPHK 8T 5 -5	436	162.5	598.5
TPHK 12T 6 -1	369	196.5	565.5
TPHK 12T 6 -2	436	196.5	632.5
TPHK 12T 9 -2	436	298.5	734.5
TPHK 12T 6 -3	436	196.5	632.5
TPHK 12T 9 -3	436	298.5	734.5

TPHK8T_E



Model	Dimensions(mm)					
	L	A	B	C	D	E
TPHK 8T2 -2E	455	284	171	231	110	145
TPHK 8T3 -3E	519	321	198	244	123	181
TPHK 8T4 -4E	546	321	225	244	123	181
TPHK 8T5 -5E	598	346	252	244	123	181
TPHK 8T6 -6E	645	366	279	244	123	181



在開始安裝與操作之前，請仔細研讀本說明書裏各項的安裝與操作說明。

1. 應用

- 1.1 本機型產品是採用多段離心式設計之泵浦。可用來傳送工具機上之液體。
- 1.2 本泵浦不可以被使用於易燃的液體輸送，諸如柴油、石油、汽油或類似的液體。適用液體包括水溶性、低黏稠度、中性之冷卻 / 潤滑液。



2. 型別說明

泵浦型別主要依加壓導室而來，有葉輪之加壓導室為標準加壓導室，配合無葉輪的空加壓導室組合，可應用於另外的尺寸場合，泵浦的型別編號由泵浦銘板上可查得。

3. 使用條件

環境溫度：Max. +40°C

液體溫度：+0°C~+90°C

防護等級：IP54

工作壓力：Max.10kg/cm²

浸水高度：Min.40mm

濾網孔徑：Ø2mm(TPHK2T,4T)

Ø3mm(TPHK8T,12T)

顆粒大小：2mm以下(TPHK2T,4T)




3mm以下(TPHK8T,12T)

水中固體顆粒含量：50g/m³

黏稠度：32cst(mm²/s)

啟動和停止的頻率：

輸出功率[kW]	次數/小時
2.2 以下	250
2.2~4.0	100



4. 裝置



馬達表面有高熱，所以安裝位置儘量避免人容易意外碰觸到的位置。

4.1 吸入狀況

為防止泵浦於低水位時乾轉受損，泵浦的最小浸泡深度需為40mm，如Fig.1。另外，泵浦底部至水箱底部距離至少需留25mm。




Fig.1

4.2 泵浦出水口，建議維持原配管尺寸，若縮小管路尺寸，將影響泵浦出水效能。

5. 電路安裝



5.1 電路必須依照各地規定的標準來安裝，於安裝泵浦電路時，必須將電源關閉。



5.2 會產生電的危險警告標示，於接線盒外明確標示，敬請小心。

5.3 泵浦使用的電壓，頻率標示於銘板上。同時請確認馬達標示的電壓、頻率與使用的電源規格相同，泵浦必須外接一個 ON / OFF 開關，並請加裝漏電斷路器 (RCD, 30mA)。

5.4 三相馬達必須接到起動裝置，並檢視指示電流是否與銘板標示相符，且馬達電路連接須與接線盒蓋標示一致。

5.5 三相電源泵浦，必須檢查轉向，由風罩端看為順時鐘方向且於馬達風罩上有箭頭標示正確轉向，若從風罩端看為逆時鐘方向，則必須更改轉向，於更改轉向前必須先切斷電源，再將其電源線其中 2 條對調。

5.6 如果電源線損壞，則必須由製造商指定服務代理商或專業的水電人員更換，以免造成危險。

5.7 泵浦須裝漏電流30 mA以下的漏電斷路器。

6. 起動

於開始起動泵浦前，須確認之操作的事項：

6.1 馬達轉向是否正確，從風罩端看，應為順時鐘方向。

6.2 全部的管路是否密閉，管路洩漏會造成泵浦壓力損失。

6.3 泵浦體需有液體存在。

6.4 濾網沒有被雜物堵塞。

7. 操作維護

於泵浦運轉時，不被允許將管路開關關閉，若是接近 5 分鐘，泵浦將受到損害。

7.1 潤滑維護

泵浦內機械軸封與軸套皆為自潤式，由傳動液體來潤滑。

7.2 濾網

須應常保持清潔，確定無雜物堵塞，如此才能維持一個最佳的液體流量。

7.3 定期檢查

在一定的操作時間，請必須作以下的檢查：

7.3.1 檢查液體的流量和操作壓力。

7.3.2 檢查管路系統是否洩漏。

7.3.3 檢查馬達的起動是否正常。

7.3.4 檢查全部的操縱器，是否都達正常的狀況。

7.4 長期停用前，請將泵浦內部液體排乾。欲重新供電啟動前請先從風扇側試轉動泵軸，確認無卡住情形；若無法轉動，請把泵浦葉輪、軸封拆卸，清潔乾淨後重組裝，確認轉動平順再供電運轉。

7.5 本泵浦禁止使用於具有爆炸危險之環境，且使用液體溫度超過60°C時需加裝防護裝置，以避免燙傷。

7.6 假如泵浦被用來操作有害人類健康的有毒液體或污染源的話，在非一般使用情形下故障，本公司將拒絕各項的維修服務，顧客個人造成的損害，須自行負擔。

7.7 如果電源線損壞，則必須用製造商或其服務代理商提供的專用電源線或組件進行更換。

8. 噪音值

電機	dB(A)
TPHK2T ** - 1	<70
TPHK2T ** - 2	<70
TPHK2T ** - 3	<70
TPHK2T ** - 4	<70
TPHK2T ** - 5	<70
TPHK2T ** - 6	<70
TPHK2T ** - 7	<70

電機	dB(A)
TPHK4T ** - 1	<70
TPHK4T ** - 2	<70
TPHK4T ** - 3	<70
TPHK4T ** - 4	<70
TPHK4T ** - 5	<70
TPHK4T ** - 6	<70


電機	dB(A)
TPHK8T ** - 2	<70
TPHK8T ** - 3	71
TPHK8T ** - 4	76
TPHK8T ** - 5	76

電機	dB(A)
TPHK8T**-2E	<70
TPHK8T**-3E	76
TPHK8T**-4E	76
TPHK8T**-5E	76
TPHK8T**-6E	76

電機	dB(A)
TPHK12T ** - 1	71
TPHK12T ** - 2	76
TPHK12T ** - 3	76

上表為泵浦出口全閉運轉噪音值，噪音值公差 $\pm 3\text{dB(A)}$

9. 結線圖




10. 故障與可能原因分析

在檢查泵浦各項故障原因前，必須確定已將電源關閉才可進行。

故障原因	可能原因分析
1. 泵浦不運轉	<ol style="list-style-type: none">1. 沒有電2. 保險絲燒毀3. 馬達啟動器之過載保護裝置已跳脫4. 馬達啟動器 / 接觸器之磁性線圈短路5. 控制跳電中斷或有問題
2. 泵浦運轉中忽然停止	<ol style="list-style-type: none">1. 保險絲燒毀2. 外接保護裝置斷路3. 控制線路損壞4. 泵浦本體受到外物阻礙
3. 泵浦流量不定水量忽大忽小	<ol style="list-style-type: none">1. 有雜質的液體阻塞了葉輪2. 水槽水位太低，請查看 4.1 章節
4. 泵浦運轉中，但沒有水流量	<ol style="list-style-type: none">1. 濾網被固體雜物堵塞2. 水位太低，低於超過泵浦能運作之低水位範圍極限，請參考 4.1 章節3. 泵浦運轉方向錯誤


11. 外型尺寸

TPHK 2T/4T




型式	A (mm)	B (mm)	L (mm)
TPHK 2T 3 -1	205.5	144	349.5
TPHK 2T 8 -1	205.5	234	439.5
TPHK 2T 3 -2	205.5	144	349.5
TPHK 2T 5 -2	205.5	180	385.5
TPHK 2T 9 -2	205.5	252	457.5
TPHK 2T 3 -3	205.5	144	349.5
TPHK 2T 4 -3	205.5	162	367.5
TPHK 2T 5 -3	205.5	180	385.5
TPHK 2T 6 -3	205.5	198	403.5
TPHK 2T 8 -3	205.5	234	439.5
TPHK 2T11-3	205.5	288	493.5
TPHK 2T 4 -4	245.5	162	407.5
TPHK 2T 6 -4	245.5	198	443.5
TPHK 2T 5 -5	245.5	180	425.5
TPHK 2T 6 -5	245.5	198	443.5
TPHK 2T 6 -6	253.5	198	451.5
TPHK 2T 8 -6	253.5	234	487.5
TPHK 2T 9 -6	253.5	252	505.5
TPHK 2T10-6	253.5	270	523.5
TPHK 2T11-6	253.5	288	541.5
TPHK 2T 7 -7	284	216	500
TPHK 4T 2 -1	205.5	144	349.5
TPHK 4T 3 -1	205.5	171	376.5
TPHK 4T 2 -2	245.5	144	389.5
TPHK 4T 3 -2	245.5	171	416.5
TPHK 4T 4 -2	245.5	198	443.5
TPHK 4T 6 -2	245.5	252	497.5
TPHK 4T 3 -3	245.5	171	416.5
TPHK 4T 4 -3	245.5	198	443.5
TPHK 4T 5 -3	245.5	225	470.5
TPHK 4T 6 -3	245.5	252	497.5
TPHK 4T 8 -3	245.5	306	551.5
TPHK 4T 4 -4	284	198	482
TPHK 4T 5 -4	284	225	509
TPHK 4T 6 -4	284	252	536
TPHK 4T 5 -5	309	225	534
TPHK 4T 8 -5	309	306	615
TPHK 4T 6 -6	309	252	561
TPHK 4T 8 -6	309	306	615

TPHK 8T/12T



型式	A (mm)	B (mm)	L (mm)
TPHK 8T 6 -2	369	196.5	565.5
TPHK 8T 9 -2	369	298.5	667.5
TPHK 8T 3 -3	369	94.5	463.5
TPHK 8T 6 -3	369	196.5	565.5
TPHK 8T 9 -3	369	298.5	667.5
TPHK 8T 4 -4	416	128.5	544.5
TPHK 8T 6 -4	416	196.5	612.5
TPHK 8T 5 -5	436	162.5	598.5
TPHK 12T 6 -1	369	196.5	565.5
TPHK 12T 6 -2	436	196.5	632.5
TPHK 12T 9 -2	436	298.5	734.5
TPHK 12T 6 -3	436	196.5	632.5
TPHK 12T 9 -3	436	298.5	734.5

TPHK8T_E



型式	尺寸(mm)					
	L	A	B	C	D	E
TPHK 8T2 -2E	455	284	171	231	110	145
TPHK 8T3 -3E	519	321	198	244	123	181
TPHK 8T4 -4E	546	321	225	244	123	181
TPHK 8T5 -5E	598	346	252	244	123	181
TPHK 8T6 -6E	645	366	279	244	123	181



WALRUS

WALRUS PUMP CO.,LTD.

Web:www.walruspump.com